



Testimony by:

United Water Pennsylvania, Inc.

Utility Response to Hurricane Irene and Tropical Storm Lee

Before

Joint Hearing of the Senate Consumer Protection and Professional Licensure and

Veterans Affairs and Emergency Preparedness Committees

Presented by:

John D. Hollenbach

Vice President and General Manager

United Water Pennsylvania

October 18, 2011

HR 1, North Office

Testimony

by

John Hollenbach, United Water Pennsylvania, Inc

Good Morning Senators. I am John Hollenbach, General Manager and Vice President of both United Water Pennsylvania and United Water Delaware.

United Water Pennsylvania provides water service to approximately 57,000 customers in portions of eight counties through four geographically separate water operations. The estimated population served is 160,000 people. The counties include Columbia, Cumberland, Dauphin, Luzerne, Perry, Schuylkill, Wyoming and York.

I will take some time this morning to discuss how Hurricane Irene and Tropical Storm Lee affected the operations and customers of United Water Pennsylvania.

First, let me recap the events of Hurricane Irene. Early predictions of Hurricane Irene and its potential impact to several United Water operations along the East Coast prompted United Water to set up a central command center in Boise, Idaho, along with setting up command centers at each of its locations. Here in Pennsylvania, we set up our command center at the Pennsylvania corporate office on East Park Drive in Harrisburg. This strategy of having both a local and national command center proved very successful, as proactive action plans were coordinated and communicated throughout the entire event. While flooding was not a major concern in PA with Hurricane Irene, high winds took its toll on all of our PA operations. At the height of the storm, we lost power at three of our water treatment facilities, eleven wells and

five pumping stations. Back-up generators kept the water flowing at the water treatment plants while we mobilized portable generators to keep the other stations in operation. Three days later when power was finally restored to all the facilities, it was reported that only 150 of our 57,000 plus customers had their water service impacted.

In addition to addressing our own issues during Hurricane Irene, UWPA received requests for assistance from water providers outside of United Water's territory. Via the PA WARN system, UWPA provided water buffalos for the Harvey's Lake residents and generator assistance for the Village of Forkston in Wyoming County and New Milford in Susquehanna County.

Tropical Storm Lee presented an entirely different set of challenges. First, unlike Hurricane Irene, the early predictions called for only minor to moderate flooding. However, by Wednesday September 7 it was now known that heavy flooding was going to impact Central PA giving us less time to react. Again, a 24-hour command center was set up at our corporate office at East Park Drive. We immediately began reaching out to the EMA, PUC, County Officials, Hospitals, Nursing Homes, large businesses and School Districts within our operating areas to keep them apprised of our plans. We kept in continuous contact with these parties throughout the event.

A storage management plan was also enacted in the event our treatment plants were unable to stay in-service. The plan would balance using storage to meet demands as well as to preserve water for fire protection. Also, water buffalos and water tankers were pre-staged to critical care customers, including the State PEMA command center, in the event the water plants would have to be shut down, due to rising waters.